

SUBMISSION .....

|                        |              |
|------------------------|--------------|
| PUBLIC WORKS COMMITTEE |              |
| 6 - AUG 2003           |              |
| RECEIVED               | a.m.<br>p.m. |



AUSTRALIAN  
Greenhouse  
Office

Parliamentary Standing Committee on Public Works  
Parliament House  
Canberra ACT 2600  
jcpw@aph.gov.au

John Gorton Building  
King Edward Terrace  
Parkes ACT 2600  
GPO Box 621 Canberra ACT 2601  
Telephone +61 2 6274 1888  
Facsimile +61 2 6274 1795  
www.greenhouse.gov.au

**Re: Construction of new Chancery, New Delhi, India**

The construction of a new Chancery, outlined in the Department of Foreign Affairs submission to the Committee dated 22 July 2003, is not directly subject to the provisions of the Commonwealth Energy Policy as detailed in the then Department of Industry, Science and Resources March 2000 publication titled *Measures for Improving Energy Efficiency in Commonwealth Operations*.

Though not a mandatory requirement, the Australian Greenhouse Office and the Department of Industry, Tourism and Resources consider that, subject to specific operational, functional and security requirements, the new building should have a total energy consumption target of no more than 500MJ per annum per square metre of space for standard office operations. This energy use target is equivalent to that set for Darwin by the Property Council of Australia 2001 Energy Performance Guidelines.

Section 19 of DFAT's submissions outlines a number of energy efficiency measures that would contribute to meeting this target. It is therefore recommended that any Public Works Committee approval for the proposed works to proceed should be made subject to the incorporation of these energy efficiency measures into the construction of the building. In addition, the modeled energy performance of the parts of the building used for standard office operations should be no higher than 500MJ per square metre per annum.

Should you require additional information please contact Ms Kay Abel at the Australian Greenhouse Office on 02 6274 1039 or fax 02 6274 1913.

James Shevlin  
Branch Head  
Built Environment and Communities Branch

4 August 2003