

**Senate Finance and Public Administration Legislation Committee
—Additional Estimates Hearing—February 2016**

Answers to Questions on Notice

Parliamentary departments, Department of Parliamentary Services

Topic: **Air conditioning**

Question: **169**

Hansard Reference **p 64; 8 February 2016**

Date set by the committee for the return of answer: 1 April 2016

Senator WONG: Let's move back. QoN 34 is not paginated but, if you count through, the bottom of page 6 is room 2, cold—and it is room 236. I just wonder if you can let me know on notice why—I understand that this often happens. Everyone in the building at times has complained about the air conditioning. But that is significantly high for one call-out.

Answer

This call out was higher than others listed as it involved the relocation of an air-conditioning sensor within the room.